

		1		2		3		4		5		6											
A	仪表	电压表、电流表 转换开关																					
	母排	相线/零线电流(A)		L11,L12,L13,N 380/220V																			
		编号:L11,L12,L13,N																					
		380/220V, 额定 1600A/800A																					
	负荷开关	型号及规格 额定电流(A) 整定电流(A)				-QL2 HD13BX-1000/31																	
	断路器	型号及规格/附件 额定电流(A)		-QF19 XT1H160 TMD63 3P +2Q1SY In=63A I3=10In		-QF21 XT1H160 TMD63 3P +2Q1SY In=63A I3=10In		-QF22 XT1H160 TMD63 3P +2Q1SY In=63A I3=10In		-QF23 XT1H160 TMD63 3P +2Q1SY In=63A I3=10In		-QF24 XT1H160 TMD63 3P +2Q1SY In=63A I3=10In											
	接触器	型号及规格 附件																					
	接触器	型号及规格 附件		-KM19 AX65-30-11		-KM21 AX65-30-11		-KM22 AX65-30-11		-KM23 AX65-30-11		-KM24 AX65-30-11											
	互感器	型号及规格																					
	热继电器	型号及规格 整定电流(A) 或额定电流(A)																					
B	母排	PE母排 额定800A																					
	线路	电缆型号/规格		ZC-YJV-0.6/1kV 5x16		ZC-YJV-0.6/1kV 5x16		ZC-YJV-0.6/1kV 5x16		ZC-YJV-0.6/1kV 5x16		ZC-YJV-0.6/1kV 5x16											
	用电设备	编号		PSLAL4		PHSAL2		PHSAL4		PFPAL2		PFPAL4											
		名称		剪切线主厂房照明配电箱#4		热处理备料跨主厂房照明配电箱#2		热处理备料跨主厂房照明配电箱#4		成品跨主厂房照明配电箱#2		成品跨主厂房照明配电箱#4											
C																							
D	二次原理图号																						
	单元号		19		21		22		23		24												
	柜号		+4ERPCC06.02																				
						部门负责人		主任工程师		主任设计师		CISDI 中冶赛迪		照明负荷中心单线系统图		图号 00260079DR3002DR025-4		A 11/15					
序次		更改原因及内容		修改人		日期		审核人		日期		审 核		设 计 师		制 图		比例 1:1		材质		质量(kg)	
1				2				3				4				5				6			